

Approval Number 240555066
Test Report: J-00487562



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

3rd October 2024

Brymec Ltd
Redlands ,
Coulsdon,
Surrey,
United Kingdom
CR5 2HT

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

SEALANTS - SCREWED JOINTS- GENERAL.

5510

'Ultra Tight Thread Sealing Cord'. White coloured (opaque) sealing cord. Apply as per manufacturer's TDS 'V1.0'. For use with water up to 85°C.

APPROVAL NUMBER: 240555066
APPROVAL HOLDER: BRYMEC LTD

The Scheme reserves the right to review approval.
Approval 240555066 is valid between May 2024 and May 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a horizontal line extending to the right.

Ian Hughes
WRAS Approvals Manager